



**WATER SUPPLY
HYDRANT SUPPLY LAY CONNECTIONS**



CANDIDATE NAME (Please Print)	DATE
CHARTER	CHARTER #

FIREFIGHTER I		PRACTICAL SKILL EVALUATION	
Primary Task	Water Supply – Hydrant - Supply Lay Connections	JPR(s)	5.3.15
Reference Source	NFPA 1001 Standard, 2013 Edition	Skill No.	17-2
Candidate Instruction	The candidate, wearing personal protective clothing, and given supply or intake hose, hose tools, and a fire hydrant, shall connect a fire department pumper to a water supply with a reverse lay and ensure connections are tight and water flow is not obstructed.		State Maximum Allotted 10 minutes

PERFORMANCE STEPS	TEST 1		RETEST 2		RETEST 3	
	P	F	P	F	P	F
REVERSE LAY CONNECTION						
Wearing complete personal protective clothing.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Grasps needed equipment and sufficient hose (spanner and hydrant wrench, necessary appliance and adapter) to reach attack pumper intake.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Anchors hose to stationary object and signals driver to start reverse lay.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Supply line is attached to attack pumper OR hose clamp is used and placed properly.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Intake hose is connected from supply pumper or hydrant and opens hydrant properly and ensures water flow is not restricted.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Prepares supply hose for connection and connects to discharge outlet of supply pumper and charges line once attack pumper is ready (releases hose clamp if used).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ensures all connections are tight.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Firefighter must have at least 70% pass mark for each skill and perform all critical points (5/7 required).	Score: ___ / 7
--	-----------------------

NUMBER OF ATTEMPTS	TEST 1	RETEST 2	RETEST 3
SCORE	<i>17</i>	<i>17</i>	<i>17</i>
TIME			
EVALUATOR COMMENTS			

PRINT NAME FIRST EVALUATOR	CERT #	SKILL TEST DATE / /
SIGNATURE FIRST EVALUATOR X		Overall Skill Sheet Score <input type="checkbox"/> Pass <input type="checkbox"/> Fail
PRINT NAME SECOND EVALUATOR	CERT #	SKILL TEST DATE / /
SIGNATURE SECOND EVALUATOR X		Overall Skill Sheet Score <input type="checkbox"/> Pass <input type="checkbox"/> Fail
PRINT NAME THIRD EVALUATOR	CERT #	SKILL TEST DATE / /
SIGNATURE THIRD EVALUATOR X		Overall Skill Sheet Score <input type="checkbox"/> Pass <input type="checkbox"/> Fail